



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE FIRE SERVICES DEPARTMENT
FIRE NO OBJECTION CERTIFICATE**



Ack. No.:	202790002020	Issue Date :	20/02/2020	
NOC:	0006705/OCCU/WGL/2020			
NOC TYPE:	OCCUPANCY*			

Valid upto	19/02/2025
Applicant Details:	THIRUMAL RAO-9247358512/H NO: 55-1-219, SITUATED AT: BHEEMARAM(V),HASANPARTHY(M),WARANGAL DIST.T.S.

Building for which NOC issued:	SKILL STORK SCHOOL (INTERNATIONAL)(THIRUMALA EDUCATIONAL SOCIETY) SITUATED AT : BHEEMARAM(V),HASANPARTHY(M),WARANGAL DIST.T.S.
--------------------------------	--

Concession in Setbacks Given in Lieu of Land Surrendered in Road Widening: **No**

Plot Area (Sq. Mtrs):	40468.60	Total Built-up Area (Sq.Mtrs):	5800.00	Height (Metres):	15.30
Open Spaces (Metres):	North Provided: (F) 21.00	South Provided: 18.00	East Provided: 15.00	West Provided: 20.00	
No. of Floors:	Cellar0,Stilt0,Ground1,Floor4,Terrace0			Occupancy Type:	EDUCATIONAL B-1 Schools up to senior secondary level

Please find below the deficits:

Open Spaces (Metres):	North : 0.00	South: 0.00	East: 0.00	West: 0.00
Staircases:	No. of Staircases	2	0	
	Minimum width of any one staircase (Metres):	3.00 + 3.00		
	Aggregate WIDTH (Metres):	6.00 mts		

Minimum Requirements for Fire Fighting Installations as per Table 7, Part-IV of C, 2016:
NB

Fire Extinguisher:	36	First Aid Hose Reel:	12	Wet Riser:	0
Down Comer:	2	Yard Hydrant:	0	Automatic Sprinkler System:	0
Manually Operated Electronic Fire Alarm Systems:	6	Terrace Tank (Litres):	25000		
Automatic Detection and Alarm System:	0	Underground Static Water Storage Tank (Litres):	50000		
Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm2 at Terrace	Type	Quantity	(Capacity in Litres/min)		
	Electrical	0	0		
	Diesel	0	0		
	Electrical	0	0		

Level
Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm²

(Capacity in Litres/min)
900

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"
* For details and conditions of No Objection Certificate, refer overleaf.

GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE

The no objection certificate for occupancy is issued subject to following conditions:

- a. On the basis of the recommendations of the building inspection committee, recommended the fire NOC.
- b. In pursuance of the orders of the Hon'ble High Court mentioned above at Sl.No. 1 of Form No. 1B and on the basis of the recommendations of the building inspection committee, this No Objection Certificate for Occupancy is issued.
- c. Any person violating the conditions of a No Objection Certificate shall be liable to be proceeded against under the provisions of Fire Service Act, 1999.
- d. The Owner/Occupier may please note that, the department will conduct surprise inspections to verify the satisfactory working condition of the fire safety systems. During the inspection, if any violation of No Objection Certificate for Occupancy conditions /non-functioning of fire safety systems is noticed , prosecution will be launched on the Owner / Occupier as per the provisions of Fire Service Act, 1999.
- e. It is the responsibility of the builder / management to apply for Renewal of No Objection Certificate for Occupancy duly remitting the user charges as per G.O.Ms.No. 71, (Home Prisons-A) Dep., dated 01-04-2010, two months before expiry of this No Objection Certificate.
- f. The floor wise built-up areas of the following building are as follows:

Floor type	Buildup area
Ground floor	1160.00 Sq mts
1 st floor	1160.00 Sq mts
2 nd floor	1160.00 Sq mts
3 rd floor	1160.00 Sq mts
4 th floor	1160.00 Sq mts
5 th floor	1160.00 Sq mts
Total	5800.00 Sq mts